

motrona GmbH Zwischen den Wegen 32 78239 Rielasingen - Germany Tel. +49 (0)7731-9332-0 Fax +49 (0)7731-9332-30 info@motrona.com www.motrona.com

ZX020

Electronic Counter



- Mini housing 48 x 24 mm (1.890 x 0.945")
- Bright LED display 6 decades/ 8mm (0.315")
- Add-on frame for 50 x 25 mm (1.969 x 0.984")
- Counting frequency 15 60 kHz (depending on operating mode)
- Selectable filter for use with mechanical inputs
- Adjustable scaling factor and divider
- 10 30 volts DC supply
- Protection class IP65 (front side)
- Applicable as event counter, differential counter, summing counter, position counter
- Power down memory (10 years)
- Easy to set up by menu support

Operating Instructions



Safety Instructions

- This manual is an essential part of the unit and contains important hints about function, correct handling and commissioning. Non-observance can result in damage to the unit or the machine or even in injury to persons using the equipment!
- The unit must only be installed, connected and activated by a qualified electrician
- It is a must to observe all general and also all country-specific and applicationspecific safety standards
- When this unit is used with applications where failure or maloperation could cause damage to a machine or hazard to the operating staff, it is indispensable to meet effective precautions in order to avoid such consequences
- Regarding installation, wiring, environmental conditions, screening of cables and earthing, you must follow the general standards of industrial automation industry
- - Errors and omissions excepted -

Version:	Description:
Zx02001b/K/hk/Jan02	valid for models before august, 2006
Zx02002a/K/hk/Dec06	60 kHz, Divider, (x4), summing mode
ZX02002b/hk/Aug07	Modification of temperature range

Table of Contents

1.	Oper	ation of the front keys	4
2.	Oper	ational parameters	5
	2.1.	Input polarity	5
	2.2.	Input filter	5
	2.3.	Input Mode of count impulses	5
	2.4.	Impulse scaling factor	6
	2.5.	Decimal point	6
	2.6.	Set/Reset mode	6
	2.7.	Set point	7
	2.8.	End of program	7
3.	Term	inal Assignments	8
4.	Deliv	ery includes:	8
5.	Spec	ifications	9
6.	Dime	ensions	10
	6.1.	Mounting without use of add-on frames	
	6.2.	Bezel 50 x 25 mm (1.969 x 0.984'') for clip mounting	10
	6.3.	Bezel 50 x 25 mm (1.969 x 0.984'') for screw mounting	10

1. Operation of the front keys

To enter the setup mode, keep both front keys down while you switch power on. You can also enter the setup mode when the unit is already powered on, by keeping both front keys down at the same time for approx. 5 seconds.

The display will then show



As soon as you release the keys, the unit starts to alternate between display of the actual parameter text and the associated setting, in a cycle of two seconds.

Press the key on the right to increment the actual set value to next.

For numeric entries, use the left key to select the decade and the right key to scroll the digit.

To continue to the next parameter, keep the left key down while you press the right key.

When you have reached the item "Endprog", you get the choice to select

-"Yes": this will store your entries to the unit and switch to normal operation.

-"No": this will start the menu again and your previous data will not be stored.

2. Operational parameters

Please enter all of the subsequent parameters, as explained in section 1.

2.1. Input polarity

InPol		InpoL	
	nPn	nPn	NPN: All inputs must switch to"0"
	PnP	PnP	PNP: All inputs must switch to "+". For Namur: Set to NPN, see 3.

2.2. Input filter

Filter		Filter	
	oFF	Off	Filter off: Counting frequency up to 60 kHz (see specifications)
	00	on	Filter on. Maximum counting frequency 30 Hz

2.3. Input Mode of count impulses

I ոՔսէ		Input	
	[הלמיר	Cnt.dir	Input A: Count input Input B: Direction select up/down
	nb. 9u	Up .dn	Differential: Input A: increments Input B: decrements
	9. 9		Summing: Input A: increments Input B: increments
	9u8d	Quad	Quadrature up/down for signals A/B, 2 x 90° Counts rising edge of input A
	2 6Rup	Quad 2	Similar to "quad", but with impulse doubling. Counts rising and falling edges of input A
	ᠳᡁᠷᠳᡕ	Quad 4	Similar to "quad", but with impulse quadrupling. Counts all edges of inputs A and B

2.4. Impulse scaling factor

FActor		Factor	
	00000 I	00.0001	Multiplies the input pulses with the factor set.
	99.9999	99.9999	Setting range 0.0001 to 99.9999. Setting "0" will not be accepted.
dı UıSo		Divider	-
	00000 I	00.0001	Divides the input pulses by the divider set.
	999999	99.9999	Setting range 0.0001 to 99.9999. Setting "0" will not be accepted.

2.5. Decimal point

d٩		dP	
		0	Sets the decimal point of the display.
	0000	0.000	(Max. 3 decimal places)

2.6. Set/Reset mode

rESnad		resmd	
	MUBUEL	Man.el	Manual Set/ Reset function by the red front key and electrical Set/ Reset by the rear input.
	no rES	No res	All Set/ Reset functions disabled.
	EL rES	El res	Electrical Set/ Reset only by input "Reset".
	[7]AnrE	Manre	Manual Set/ Reset only by the red front key.

2.7. Set point

SEEPE		Setpt	
	-1999999	-199999	Upon a Set/ Reset command, the counter sets to the value entered here.
	999999	99.9999	Range – 199 999999 999.

2.8. End of program

EndPro		Endpro	
	00	No	Select "No" to return to the beginning of the menu for verification of settings.
	985	Yes	Select "Yes" to store data and exit the menu.

3. Terminal Assignments

(also printed to the top of the unit)



4. Delivery includes:

- Panel mounting clip
- Bezel for screw mounting with panel cut out 50 x 25mm
- Bezel for clip mounting with panel cut out 50 x 25mm
- Sealing

5. Specifications

Power supply UB	:	1030 Vdc, max. 50 mA	
Display	:	6 Decade / 8mm (0.315'')	
Inputs	:	3 x NPN / PNP / Namur, Ri = 10 kOhm	
Counting frequency	:	depending on operating conditions, see table 30 Hz with filter switched on	
Minimum pulse width for Reset	:	5 msec	
Switching thresholds of inputs	Switching thresholds of inputs : Low = 0V0.2 x UB High = 0.6 x UB30V		
Shape of input wave	:	any (Smith trigger inputs)	
Data retention		10 years, 10 ⁶ store cycles	
Operating temperature		-20° + 55° C (-4 +131° F)	
Storage temperature		-25° + 70° C (-13 +158° F)	
Weight		50g	
Protection class (front side only) : IP		IP 65	
Conformity and Standards		EMC 89/336/EEC: EN 61000-6-2 EN 61000-6-3	
		LV73/23/EEC: EN 61010-1	

Maximum counting frequency with respect to operating mode and power supply:

Mode	Input power 24 VDC	Input power 12 VDC
CntDir	60 kHz	20 kHz
Up-Down	25 kHz	15 kHz
Up-Up	25 kHz	15 kHz
Quad	25 kHz	15 kHz
Quad2	25 kHz	15 kHz
Quad4	15 kHz	15 kHz

6. Dimensions

6.1. Mounting without use of add-on frames



6.2. Bezel 50 x 25 mm (1.969 x 0.984") for clip mounting



6.3. Bezel 50 x 25 mm (1.969 x 0.984") for screw mounting

